

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. UPJN(R)PBH/DL/6461/SC-5

Dated: 05/08/2026

It is certified that an inspection team headed by Aignvijay Singh

(Name of Officers with designation) from UP Jal Nigam (Rural) PBH PHED

inspected the **Pt. Nagesh Dutt Public School, Ajhara,,Lalgaanj ,Pratapgarh**

(Name & Address of the school) on 03/08/2026 (date of inspection) and on the basis of


Water Test Report (Attached) bearing no. UPJN(R)PBH/DL/6461 dated 05/08/2026

of UP Jal Nigam (R) Pratapgarh (PHED Lab) certified that

the **Pt. Nagesh Dutt Public School** (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 05/08/2027

Signature with Seal:
Name :
Designation :
Name & Address of the Office / Department :



To
Pt. Nagesh Dutt Public School

Ajhara,,Lalgaanj ,Pratapgarh

(Name & Address of the Institution)



Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



Test Report

District Level Water Analysis Laboratory, U.P. Jal Nigam (Rural) Pratapgarh
Address- District Level Water Analysis Laboratory, U.P. Jal Nigam (Rural) Sukhpalnagar, Pratapgarh-230002

Report No:	UPJN(R)/PBH/DL/6461	Issue Date:	05/08/2026		
Remark				Page No	1/1
Contact Person:	Digvijay Singh	Address:	UPJN(R) pratapgarh	Mob:	9169048466

Customer Details

Office Name and Address	PT.Nagesh Dutt Public School, Lalganj Ajhara,Pratapgarh
Ref Letter No & Date	02/08/2026

Basic details of sample

District	Pratapgarh	Block	-
Gram Panchayat	-	Village	-
Habitation	-	Location	PT Nagesh Dutt Public school campus
Water Source	Submersible pump	Sample No.	S-6461
Quantity of Sample	1 ltr	Date of Collection	02/08/2026
Receiving Date	02/08/2026	S. Collector	Sri Shyam Shankar Mishra
Sample Depositor	Sri Shyam Shankar Mishra	Sampling Method	As per IS 17614: Part 1 : 2021
Analysis Start Date	03/08/2026	Analysis Completion Date:	03/08/2026
Temperature : 24.4c		Humidity: 52%	

Technical Data of Analysis



	Analyzed parameters (Unit of Measurement)	Observed Value	Specified Values as per BIS		Ref. Method of Analysis
			Acceptable Limit	Permissible Limit	
1	2	3	4	5	6
1	pH	7.35	6.5-8.5	6.5-8.5	IS 3025 (Part 11):2022 (Electrometric method)
2	Turbidity NTU	0.86	1	5	IS 3025 (Part 10):2023
3	TDS mg/L	80	500	2000	IS 3025 (Part 16):2023
4	Fluoride mg/L	0.440	1	1.5	IS 3025 (Part 60):2023(Electrode Method)
5	Total Hardness mg/L	108.32	200	600	IS 3025 (Part 21):2023
6	Total Alkalinity mg/L	92	200	600	IS 3025 (Part 23):2023
7	Chloride mg/L	30	250	1000	IS 3025 (Part 32):2025
8	Calcium(as Ca) mg/L	19.23	75	200	IS 3025 (Part 40):2024
9	Magnesium (asMg) mg/L	14.58	30	100	IS 3025 (Part 46):2023
10	Colour	1	5	15	IS 3025 (Part 4):2021(Visual comparison method)
11	Odour	Agreeable	Agreeable / Disagreeable		IS 3025 (Part 8):2018
12	Taste	Agreeable	Agreeable / Disagreeable		IS 3025 (Part 5):2023

Note:-

1. This Certificate refers only to the particular sample(s) submitted for testing.
2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract.
3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
4. Sample will be stored up to 07 days (in case of non-perishable items only) from the date of issue of tests reports.

Prepared By- *A*
Deputy Technical Manager

Digvijay Singh
(Quality/Technical manager)
Authorized Signatory



-----End of Report-----X